



OFFICE OF COUNTY MAYOR GLENN JACOBS

Knox County Health Department • 140 Dameron Avenue, Knoxville, TN 37917-6413

Brian Rivera, P.E.
Division Director Air Quality
Knox County Health Department
140 Dameron Ave,
Knoxville, TN 37917-6413

June 7, 2021

Re: Second Quarter Air Monitoring
Audit

Dear Mr. Rivera:
On June 2nd, 3rd, and 7th, 2021 the internal quality assurance performance audits were performed on Air Quality's monitoring network. All of the monitors audited were within the acceptable range for critical criteria.

Each physical location was inspected. As noted on the following instrument audit results, many of the instruments were dusty and/or had evidence of cobwebs. The Program Manager and operators were notified of the need for additional cleaning.

The AV Trend software was not collecting data at the Springhill site, however the East Knox site was working as expected.

The laboratory clean room was inspected. The filter preparation area was clean. The PM2.5 storage temperature log was reviewed. Storage temperatures did not exceed 4.1 degrees C when filters were stored.

If there are any questions regarding this audit please email Rebecca.Larocque@knoxcounty.org or call 865-215-5941

A handwritten signature in blue ink that reads "Rebecca Larocque".

Rebecca Larocque
Environmental Specialist
Knox County Health Department

Ozone Audit Calculations

Date: 6/3/2021
 Site: Springhill

Audit SN: 179
 Analyzer SN: 4005

Date: 6/2/2021
 Site: East Knox



Audit SN: 179
 Analyzer SN: 4006

Collection Time	Target	Analyzer	Audit Standard	Difference	% Difference
est	ppb	ppb	ppb	ppb	%
8:07:00 AM	110	110	110	0.0	0.00
8:17:00 AM	70	70	70	0.0	0.00
8:28:00 AM	35	35	35	0.0	0.00
8:39:00 AM	15	14	15	-1.0	-6.67
8:50:00 AM	0	1	0	1.0	N/A

Collection Time	Target	Analyzer	Audit Standard	Difference	% Difference
est	ppb	ppb	ppb	ppb	%
8:11:00 AM	110	109	110	-1.0	-0.91
8:22:00 AM	70	69	70	-1.0	-1.43
8:32:00 AM	35	34	35	-1.0	-2.86
8:44:00 AM	15	14	15	-1.0	-6.67
8:54:00 AM	0	0	1	-1.0	NA

Slope 0.998094 correlation 0.999874
 Intercept 0.09 R2 0.999749

Slope 1.000000 correlation 1.000000
 Intercept -1.00 R2 1.000000



Power blinked @8:42 est during zero, instruments remained on, restarted external pump and solinoid swapped for a brief moment. AV Trend Not working

Cobwebs near Hvac exhaust, suggest sweep/ vacuum shelter. Reminder to inspect fire extinguisher

PM 2.5 Audit Calculations

Reference device used for Audit: SLP

Serial number : HL-190706

Date of Certification: Jun-20

Date: 6/1/2021

Site: Air Lab

Monitor Serial number: B225760909

Thermo 2025

	units	System Value	Reference Value	Difference (S-R)	%	Acceptance Criteria
Time	hh:mm:ss	8:44:13 AM	8:44:32 AM	0:00:19		+/- 1 Min.
Filter T	°C	22.7	23	-0.3		+/- 2° C
Ambient T	°C	21.5	21.1	0.4		+/- 2° C
Pressure	mmHg	738	742	-4		+/- 10 mmHg
Flow Rate	lpm	16.71	16.98	-0.27	-1.59%	+/- 4%

Notes: LC Passed 2 mmHg PM 10 head was dirty, operator replaced with clean

Date: 6/1/2021

Site: Rule

Monitor Serial number: W2909512601

Thermo 2025

	units	System Value	Reference Value	Difference (S-A)	%	Acceptance Criteria
Time	hh:mm:ss	10:21:00 AM	10:21:00 AM	0:00:00		+/- 1 Min.
Filter T	°C	25.7	26.7	-1		+/- 2° C
Ambient T	°C	24.4	24.4	0		+/- 2° C
Pressure	mmHg	740	739	1		+/- 10 mmHg
Flow Rate	lpm	16.68	16.93	-0.25	-1.48%	+/- 4%

Notes: LC passed 6mmHG

Date: 6/1/2021

Site: AirLab

Monitor Serial number: 192

T640 X

	Units	System	Reference	Difference	%	Criteria
Time	hh:mm:ss	9:13:54 AM	9:13:53 AM	0:00:01		+/- 1 Min.
Shelter T	°C	30	28	2		+/- 2° C
Amb T	°C	24.4	24.8	-0.4		+/- 2° C
Pressure	mmHg	739.3	741.3	-2		+/- 10mmHg
Total Flow	lpm	16.8	16.9	-0.1	-0.59%	+/- 4 %
MainFlow	lpm	4.9	4.95	-0.05	-1.01%	+/- 4 %

Notes: LC Passed shelter T serial # 140793699, Very dusty (pollen) and dirty inside shelter, evidence older cobwebs

Date: 6/1/2021

Site: Rule

Monitor Serial number: 675

T640

	Units	System	Reference	Difference	%	Criteria
Time	hh:mm:ss	10:42:10 AM	10:42:12 AM	0:00:02		+/- 1 Min.
Shelter T	°C	29.5	27.5	2		+/- 2° C
Amb T	°C	25.2	25	0.2		+/- 2° C
Pressure	mmHg	736.1	738.9	-2.8		+/- 10mmHg
Flow Rate	lpm	5	5.07	-0.07	-1.38%	+/- 4 %

Notes: Logbook, maintenance stickies in place but not utilized. Shelter thermometer SN200638909

Date: 6/2/2021

Site: Springhill

Monitor Serial number: 910

T640

	Units	System	Reference	Difference	%	Criteria
Time	hh:mm:ss	10:25:00 AM	10:25:03 AM	0:00:03		+/- 1 Min.
Shelter T	°C	28	26	2		+/- 2° C
Amb T	°C	24.3	24.7	-0.4		+/- 2° C
Pressure	mmHg	735	736.1	-1.1		+/- 10mmHg
Flow Rate	lpm	4.95	5.12	-0.17	-3.32%	+/- 4 %

Notes: Extremely dusty in shelter, shelter thermometer SN99287906

Speciation Audit Calculations

Reference device used for Audit: **SLP**

Serial number : HL190706

Date of Certification: Jun-20

Leak Test		
	Pass	Fail
URG 3000	47	
SASS Channel 1	0	
SASS Channel 2	0.1	

Pressure {Ambient}			
	System	Reference	Difference
URG 3000N	734.2	736.2	-2.00
SASS	736	736	0.00

Flow Rate

	System	Reference	% Difference
URG 3000N	21.97	22.25	-1.26%
SASS channel 1	6.7	6.9	-2.90%
SASS Channel 2	6.6	6.8	-2.94%

Temperature

	System	Reference	Difference
URG 3000N Ambient	22.9	23.8	-0.90
SASS ambient	23.7	23.5	0.20
SASS filter channel 1	24.5	24.8	-0.30
SASSfilter Channel 2	24	24	0.00

TSP 1-point Flow Verification

Site: Ameristeel

Operator's Orifice: Z87

Audit Stnd: 91004702

Date: 6/7/2021

manometers: 91022312

Technician: Rebecca Larocque

Monitor:

Model: Andersen/GMW Hi-Vol

VFC SN: P-04304

slope (m) 1.561 (TS Orifice calibration curve)

Intercept (b) 0.006

Sec 2.7.2, Step 4

T_a = 23.9 °C (obs) = 296.9 °K (conv)

P_a = 739.1 mm Hg (obs) = 29.1 in Hg (conv)

P_{std}/T_{std} = 0.1004

T_{std}/P_{std} = 9.959893

Pass Leak Test? Yes No

ΔH_2O = 3.0 in H₂O

ΔP_{stag} = 25.9 in H₂O = 48.4 mmHg

With Orifice and Filter

Sec 2.7.2, Step 7

With Orifice and Filter

$Q_a = (y-b)/m$

Q_{std} orif (calc) = 1.0924 m³/min = 1.092 m³/min

cfm

$y = \sqrt{[\Delta H_2O \times (P_{std}/T_{std}) T_a / P_a]}$

$Q_a = \frac{(\sqrt{[\Delta H_2O \times (P_{std}/T_{std}) T_a / P_a]} - b)}{m}$

P_j/P_a = 0.9345

Q_a orif (tab) = 1.1420 m³/min

$P_j/P_a = 1 - (\Delta P_{stag}/P_a) =$
Absolute Stagnation Pressure Ratio

Q_{std} orif (tab) = $Q_{std} (P_j/T_a) (T_{std}/P_{std}) = Q_{std} (T_a/P_a)(9.9599)$

Use the Absolute Stagnation Pressure Ratio (P_j/P_a) and the temperature (T_a) to find the actual flowrate (Q_a) in the monitor's look up table.

Q_{std} orif (tab) = 1.1148 m³/min

% difference between orifice flow rate and sampler flow rate

With Orifice and Filter

QC % difference = 100 X $\frac{Q_{std}$ orif (tab) - Q_{std} orif (calc)}{ Q_{std} orif (calc)} = 2.04 %

Is this value \leq 7.1%? Yes No

if yes, continue
if no, investigate

Without orifice. Filter in a cassette only

$P_j/P_a = 1 - (\Delta P_{stag}/P_a) =$ Absolute Stagnation Pressure Ratio

ΔP_{stag} = 27 in H₂O = 50.4 mmHg

Without Orifice. Filter in cassette only

P_j/P_a = 0.9317

Q_a samp = 1.139 m³/min

Use the Absolute Stagnation Pressure Ratio (P_j/P_a) and the temperature (T_a) to find the actual flowrate (Q_a) in the monitor's look up table.

$Q_{std} = Q_a * (Pa/Ta) * Tstd/Pstd = Q_a (Pa/Ta) * 9.9599$

Q_{std} = 1.111828981 m³/min 39.2639 cfm

Q_a correct

Without Orifice. Filter Only

Q_a correct = $\frac{Q_a \text{ samp} \times (100 - \% \text{ diff})}{100}$ = 1.0891 m³/min

% difference between Q_a correct and Q_a design

% difference = 100 X $\frac{Q_a \text{ correct} - 1.130}{1.130}$ = -3.62 %

Is this \leq 10%? Yes No

if yes, flow check has been passed
if no, investigate

Note: Design flow rate = 1.13 m³/min

Note: If % diff is \geq 6 % notify site operator.

Reference Method 2.2 *Determination of Suspended Particulates in the Atmosphere (High-Volume Method)

TSP 1-point Flow Verification

Site: Burnside

Operator's Orifice: Z87

Audit Stnd: 91004702
manometers: 91022312

Date: 6/7/2021

Technician: Rebecca Larocque

Monitor:
Model: Andersen/GMW Hi-Vol
VFC SN: P-02875

slope (m) 1.561 (TS Orifice calibration curve)
Intercept (b) 0.006

Sec 2.7.2, Step 4

T_a = obs 22.7 °C = conv 295.7 °K
 P_a = 739 mm Hg = 29.1 in Hg

P_{std}/T_{std} = 0.1004
 T_{std}/P_{std} = 9.959893

Pass Leak Test? Yes No

ΔH_2O = <u>3.2</u> in H ₂ O	With Orifice and Filter
ΔP_{stag} = <u>25.6</u> in H ₂ O = 47.8 mmHg	

Sec 2.7.2, Step 7

With Orifice and Filter

$$Q_a = (y-b)/m$$

$Q_{std\ orif\ (calc)}$ = 1.1306 m³/min = 1.131 m³/min cfm

$$y = \sqrt{[\Delta H_2O \times (P_{std}/T_{std}) \times T_a/P_a]}$$

$$Q_a = \frac{(\sqrt{[\Delta H_2O \times (P_{std}/T_{std}) \times T_a/P_a]} - b)}{m}$$

P_j/P_a = 0.9353

$Q_a\ orif\ (tab)$ = 1.1260 m³/min

$$P_j/P_a = 1 - (\Delta P_{stag}/P_a) = \text{Absolute Stagnation Pressure Ratio}$$

$$Q_{std\ orif\ (tab)} = Q_{std} \times (P_j/T_a) \times (T_{std}/P_{std}) = Q_{std} \times (T_a/P_a) \times 9.9599$$

Use the Absolute Stagnation Pressure Ratio (P_j/P_a) and the temperature (T_a) to find the actual flowrate (Q_a) in the monitor's look up table.

$Q_{std\ orif\ (tab)}$ = 1.1034 m³/min

% difference between orifice flow rate and sampler flow rate
With Orifice and Filter

QC % difference = 100 X $\frac{Q_{std\ orif\ (tab)} - Q_{std\ orif\ (calc)}}{Q_{std\ orif\ (calc)}} = -2.40\ \%$

Is this value $\leq 7.1\ \%$? Yes No

if yes, continue
if no, investigate

Without orifice. Filter in a cassette only

$$P_j/P_a = 1 - (\Delta P_{stag}/P_a) = \text{Absolute Stagnation Pressure Ratio}$$

ΔP_{stag} = <u>19.2</u> in H ₂ O = 35.9 mmHg	Without Orifice. Filter in cassette only
---	--

P_j/P_a = 0.9515

$Q_a\ samp$ = 1.148 m³/min

Use the Absolute Stagnation Pressure Ratio (P_j/P_a) and the temperature (T_a) to find the actual flowrate (Q_a) in the monitor's look up table.

$$Q_{std} = Q_a \times (Pa/Ta) \times T_{std}/P_{std} = Q_a \times (Pa/Ta) \times 9.9599$$

Q_{std} = 1.12500969 m³/min 39.7293 cfm

Q_a correct

Without Orifice. Filter Only

$Q_a\ correct$ = $\frac{Q_a\ samp \times (100 - \% diff)}{100} = 1.1520\ m^3/min$

% difference between Q_a correct and Q_a design

% difference = 100 X $\frac{Q_a\ correct - 1.130}{1.130} = 1.95\ \%$

Is this $\leq 10\ \%$? Yes No

if yes, flow check has been passed
if no, investigate

Note: Design flow rate = 1.13 m³/min

Note: If % diff is $\geq 6\ \%$ notify site operator.

Reference Method 2.2 *Determination of Suspended Particulates in the Atmosphere (High-Volume Method)

TSP 1-point Flow Verification

Site: Burnside Collocated

Operator's Orifice: Z87

Audit Stnd: 91004702

Date: 6/7/2021

manometers: 91022312

Technician: Rebecca Larocque

Monitor:
Model: Andersen/GMW Hi-Vol
VFC SN: P-04302

slope (m) 1.561 (TS Orifice calibration curve)
Intercept (b) 0.006

Sec 2.7.2, Step 4

T_a = 22.7 °C (obs) = 295.7 °K (conv)
 P_a = 739 mm Hg = 29.1 in Hg

P_{std}/T_{std} = 0.1004
 T_{std}/P_{std} = 9.959893

Pass Leak Test? Yes No

ΔH_2O = <u>3.1</u> in H ₂ O	With Orifice and Filter
ΔP_{stag} = <u>25.8</u> in H ₂ O = 48.2 mmHg	

Sec 2.7.2, Step 7

With Orifice and Filter

$$Q_a = (y-b)/m$$

$Q_{std\ orif\ (calc)}$ = 1.1127 m³/min = 1.113 m³/min cfm

$$y = \sqrt{[\Delta H_2O \times (P_{std}/T_{std}) T_a/P_a]}$$

$$Q_a = \frac{(\sqrt{[\Delta H_2O \times (P_{std}/T_{std}) T_a/P_a]} - b)}{m}$$

P_j/P_a = 0.9348

$Q_a\ orif\ (tab)$ = 1.1300 m³/min

$$P_j/P_a = 1 - (\Delta P_{stag}/P_a) = \text{Absolute Stagnation Pressure Ratio}$$

$$Q_{std\ orif\ (tab)} = Q_{std} (P_j/T_a) (T_{std}/P_{std}) = Q_{std} (T_j/P_a)(9.9599)$$

Use the Absolute Stagnation Pressure Ratio (P_j/P_a) and the temperature (T_a) to find the actual flowrate (Q_a) in the monitor's look up table.

$Q_{std\ orif\ (tab)}$ = 1.1074 m³/min

% difference between orifice flow rate and sampler flow rate
With Orifice and Filter

$$QC\ \% \text{ difference} = 100 \times \frac{Q_{std\ orif\ (tab)} - Q_{std\ orif\ (calc)}}{Q_{std\ orif\ (calc)}} = -0.48\ \%$$

Is this value \leq 7.1%? Yes No

if yes, continue
if no, investigate

Without orifice. Filter in a cassette only

$$P_j/P_a = 1 - (\Delta P_{stag}/P_a) = \text{Absolute Stagnation Pressure Ratio}$$

ΔP_{stag} = <u>20.1</u> in H ₂ O = 37.6 mmHg	Without Orifice. Filter in cassette only
---	--

P_j/P_a = 0.9492

$Q_a\ samp$ = 1.148 m³/min

Use the Absolute Stagnation Pressure Ratio (P_j/P_a) and the temperature (T_a) to find the actual flowrate (Q_a) in the monitor's look up table.

$$Q_{std} = Q_a * (Pa/Ta) * Tstd/Pstd = Q_a (Pa/Ta) * 9.9599$$

Q_{std} = 1.12500969 m³/min 39.7293 cfm

Q_a correct

Without Orifice. Filter Only

$$Q_a\ correct = \frac{Q_a\ samp \times (100 - \% \text{ diff})}{100} = \underline{1.1304\ m^3/min}$$

% difference between Q_a correct and Q_a design

$$\% \text{ difference} = 100 \times \frac{Q_a\ correct - 1.130}{1.130} = \underline{0.04\ \%}$$

Is this \leq 10%? Yes No

if yes, flow check has been passed
if no, investigate

Note: Design flow rate = 1.13 m³/min

Note: If % diff is \geq 6 % notify site operator.

Reference Method 2.2 *Determination of Suspended Particulates in the Atmosphere (High-Volume Method)