



STATE OF TENNESSEE
TENNESSEE WILDLIFE RESOURCES AGENCY

**INVITATION FOR BID # 32801-12261
AMENDMENT # 1
FOR TWRA Lake Graham Pier**

DATE: **March 31, 2022**

ITB # 12261 IS AMENDED AS FOLLOWS:

1. State responses to questions and comments in the table below amend and clarify this ITB.

Any restatement of ITB text in the Question/Comment column shall NOT be construed as a change in the actual wording of the ITB document.

QUESTION / COMMENT	STATE RESPONSE
1. Section 1.6 - Substructure - calls out substructure (Fishing Pier) to be welded steel, modular box truss design. Our standard floating dock designs are welded aluminum substructure. Would this be acceptable?	Yes.
2. Section 1.9 - Rubrail - calls out 2x6 wood rub rail. Our standard rub rail is a rubber material that fits integrally into a track of our aluminum main frame material used on the perimeter of our floating docks. Would this be acceptable?	Yes.
3. Section 1.3.G. - Handrails - Spec has general statement that handrails on gangway, ramp and dock are to be ADA compliant. However, there is no specifics on what the railing for the docks needs to be. Must there be railing around the entire perimeter of the floating dock? Does the railing require sections that are handicap accessible?	Railing shall be built and installed at current ADA height and spacing requirements around entire pier. There shall be a certain percentage of handicap accessible fishing spots on the pier. 25% of available fishing spaces must be ADA accessible.

QUESTION / COMMENT	STATE RESPONSE
<p>4. The specifications do not call out the design or installation of concrete foundations for attachment of gangways, anchorage points or cables as part of the scope of work. We would not be including the cost to design or build foundations in our bid.</p>	<p>This cost shall be included in the Respondent's bid price. Please see specifications Section 1.1.</p>

2. **ITB Amendment Effective Date.** The revisions set forth herein shall be effective upon release. All other terms and conditions of this ITB not expressly amended herein shall remain in full force and effect.