



STATE OF TENNESSEE  
TENNESSEE WILDLIFE RESOURCES AGENCY

**INVITATION FOR BID # 32801-12351  
AMENDMENT # 1  
FOR TWRA Pickwick Lake Pier**

DATE: May 11, 2022

ITB # 12351 IS AMENDED AS FOLLOWS:

**1. State responses to questions and comments in the table below amend and clarify this ITB.**

Any restatement of ITB text in the Question/Comment column shall NOT be construed as a change in the actual wording of the ITB document.

QUESTION / COMMENT	STATE RESPONSE
How will the docks be anchored? Piles or Cable? If Piles, will they be internal or external?	The piers will be attached by cables, walkways, or stiff arms.
Are adjustable cleats a fixed spec or is there room for an alternate?	Adjustable cleats
Will the 10 x 25 sections be hinged or bolted connection?	The 10 X 25 foot sections should be built such that more sections could be added in the future or a section removed for repair if necessary. If this requirement can be achieved by hinge and/or bolting, we would accept either option.
1.	

QUESTION / COMMENT	STATE RESPONSE
2.	
3.	

2. **ITB Amendment Effective Date.** The revisions set forth herein shall be effective upon release. All other terms and conditions of this ITB not expressly amended herein shall remain in full force and effect.