



STATE OF TENNESSEE
DEPARTMENT OF TENNESSEE WILDLIFE RESOURCE AGENCY

**REQUEST FOR PROPOSALS # 32801-12832
AMENDMENT #1
FOR TWRA CATOOSA WMA PREFABRICATED
BUILDING**

DATE: June 23, 2023

ITB # 32801-12832 IS AMENDED AS FOLLOWS:

1. State responses to questions and comments below amend and clarify this ITB.

Any restatement of ITB text in the Question/Comments shall NOT be construed as a change in the actual wording of the ITB document.

PAGE #	QUESTION / COMMENT	STATE RESPONSE
	1. This appears to be a rebid of the April procurement event that was cancelled. Please advise if there is any difference between this procurement, and the April procurement for TWRA Catoosa WMA Prefabricated Building - Procurement Event 32801-0000012740	See Section F. 1. Delivery date changed.
	2. Please advise context for the "Tech Tips" attachment - Is the Romtec product now being specified?	See D.4 in Specifications--Sweet Smelling Technology (SST). SST Attachment provides details on how to incorporate SST into build. Romtec or equivalent would not be an acceptable make/model.
	3. Do you have a contact name and info for Romtec?	See page 3 of the SST (Sweet Smelling Technology) Attachment for contact information.
	4. A timed locking system installed on the units. <ul style="list-style-type: none"> If the vendor does not offer timed locking mechanisms. Would a standard, keyed deadbolt or padlock locking mechanism be acceptable? 	Time locks are required for security.
	5. A lined vault <ul style="list-style-type: none"> If the Vendor does not provide lined vaults for Concrete vault latrines. Would the following method be acceptable? The Vendor coats the vaults with a concrete sealer (Tamoseal) which is found to hold up better over time allowing the company to warranty the vaults for a longer period. 	No, Tamoseal is not acceptable

2. ITB Amendment Effective Date. The revisions set forth herein shall be effective upon release. All other terms and conditions of this ITB not expressly amended herein shall remain in full force and effect.