



STATE OF TENNESSEE  
Department of Correction

**INVITATION TO BID # 32906-13009  
AMENDMENT # 1  
FOR ROOF REPLACEMENT TN CORRECTION  
ACADEMY**

DATE: 11/15/2023

ITB # 32906-13009 IS AMENDED AS FOLLOWS:

**1. State responses to questions and comments in the table below amend and clarify this ITB.**

Any restatement of ITB text in the Question/Comment column shall NOT be construed as a change in the actual wording of the ITB document.

ITB SECTION	PAGE #	QUESTION / COMMENT	STATE RESPONSE
		1. Is this a full tear off to the concrete deck? Item 2,3 & 4 on the Specs do not clarify that completely to me. It says remove ballast and slice existing EPDM roof membrane.	Yes, all existing roofing material is to be removed prior to the installation of the new roof. Please see item 3 below.
		2. Does it need to be a new fully tapered ISO sloped to the existing roof drains on a 1/8" per foot? Then a 1/2" cover board on top of the new tapered ISO insulation? Being a concrete deck, the tapered ISO and cover board will need to be foam adhered from the decking up I would assume?	Yes
		3. The specifications call out .90 mil EPDM Membrane to be used. This is a much thicker product which does significantly increase the quote. Can we get approval to quote and install a .60 mil EPDM Membrane if awarded?	The material should be 90 mil White EPDM, designed to FM-90 standard (for adhesion).
		4. Does the State have any architectural drawings or plans	Yes, some drawings are available – please see attachment 1 to this amendment.

**2. Add the following as ITB Amendment 1 Attachment 1**  
**UNIFORM WHSE BUILDING DRAWINGS.ZIP**

**3. Delete ITB Specifications in its entirety and insert the following in its place (any sentence or paragraph containing revised or new text is highlighted):**  
**Uniform Warehouse Specs v3.pdf**

- 
4. **ITB Amendment Effective Date.** The revisions set forth herein shall be effective upon release. All other terms and conditions of this ITB not expressly amended herein shall remain in full force and effect.