



REQUEST FOR INFORMATION

- **Contract Number: CNR048**
- **Project: Interstate 24, Bridge Replacement over Spring Street and Oldham Street**
- **Date:**
- **Question:**

Note 6 on drawing BR-122-59 states "Clean Existing Deck Drainage System". What is the intent of this item? Is this just for the Cumberland River Bridge? Is a flush sufficient or a camera scope of each drain required? What is the extent of the drain system in question?

- **TDOT Response:**

This item refers to the parapet drains on the bridge. We want to ensure that after them milling and paving , that the drains are free and clear.

* Please email questions to Jamie Fitzpatrick at Jamie.Fitzpatrick@tn.gov.